



FIRE RATING INFORMATION GENERAL PURPOSE LAMINATES

Nevamar General Purpose Laminates Fire Rating Information

Testing Service: Hardwood Plywood & Veneer Association Laboratory and Testing Service

Test Method: ASTM E 84 Twenty Five Foot Tunnel Furnace Test Method"

Date of Report: May 2, 2003

Test Results:

Grade	Flame Spread Index	Smoke Developed Index
Nevamar® HGS, Horizontal general purpose Unbonded (no substrate_	60	105
Nevamar® VGP Vertical postforming Unbonded (no substrate)	40	70

The test results indicate the above products meet the requirements for a Class B fire rating.